



Initiation of turn-by-turn optics measurement at SLS

M. Aiba, M. Böge, J. Chrin, N. Milas, T. Schilcher and A. Streun XVIII ESLS work shop @ ELETTRA, Trieste, Italy 24-26 Nov. 2010

XVIII ESLS WS @ ELETTRA, 25/11/2010

Masamitsu Aiba, PSI





- Status of optics measurement/correction at SLS
 - Beta function with quadrupole variation (Tune response)
 - Linear coupling with orbit response (partial LOCO)
 - Dispersion
 - Hor: No explicit correction (correction through beta correction)
 - Ver: Correction together with coupling.
 - Skew Qs at dispersive and non-dispersive section
 - Nonlinear optics with resonance driving term knobs
 - Somehow empirical as looking at beam lifetime
- Motivation for turn-by-turn (TBT) measurement
 - TBT capability has not been fully utilized
 - Used for injection (first few turns) and decoherence measurements
 - Better understanding the optics, complementary to the methods currently used
 - Aiming at even better correction!






- Setup for TBT measurement
 - Use pingers to excite betatron oscillation in both planes, oscillation ~1 mm or more
 - Beam current: 50 mA/100 buckets (out of 480 buckets)
 - Avoid collective effects (cf. 400 mA / 390 buckets in user operation)
 - Short bunch train to match pinger pulse length ($<\tau_{rev}$)
 - Side effect: Machine temperature lower than in user operations (see later slide)
 - BPMs: turn-by-turn mode, noise ~20 μ m
 - "One click" application to collect and validate ~2000 turns data from all BPMs

FAUL SCHERRER INSTITUT SWISS LIGHT SOURCE SWISS LIGHT SOURCE


• BPM triggering



- Issue
 - Artifact in measured betatron phase related with BPM triggering
 - Similar experience at Diamond

(Ref. R. Bartolini / R. Hrovatin 2nd Nonlinear beam dynamics workshop)

Masamitsu Aiba, PSI



Introduce cable delay to adjust triggers at each BPM

Difference phase advance between measured and model

BPM sectors layout

• Upgrade (16/11/2010)

PAUL SCHERRER INSTITUT

Trigger issue/upgrade (2)










• TBT data quality (Statistical error)




Phase advance measurement error

Tunes from all BPM Hor. σ 6~8×10⁻⁶ Ver. σ >10⁻⁵

Horizontal: Satisfactory Vertical: Need understanding PAUL SCHERRER INSTITUT

- Phase measurement following beam dump
 - TBT measurement is fast and capable to take "optics snapshot"



Optics is constant over hot and cold machine, justifying TBT measurement at low current Optics measurement with Q-variation, ~1 hour with 50~100 mA, as well is OK Note that the orbit is drifting... (Orbit feedback was off during the measurement)

XVIII ESLS WS @ ELETTRA, 25/11/2010

Masamitsu Aiba, PSI

SWISS LIGHT SOURCE





- Summary
 - TBT measurement at SLS has been started
 - BPM trigger adjusted with cables
 - It is revealed that the optics is constant over hot and cold machine, justifying TBT measurement as well as Q-variation
- Plans
 - Comparisons
 - Beta function at quads and BPMs with a reconstructed error model
 - Q-variation, TBT and (Full) LOCO also recently tested at SLS
 - Nonlinear optics optimization, check what is going on with the method currently used (Ref. R. Bartolini et. al., Correction of multiple nonlinear resonances in storage rings, PRSTAB 11, 2008)
 - Coupling correction
 - With resonance driving term
 - With vertical bumps at sextupoles together with vertical dispersion, non-orthogonal knob approach

(Ref. G. Vanbavinckhove et. al., SPS coupling correction, IPAC10)

- (Impedance localization)